



**Office of the District Fire Officer,
Karnataka Fire & Emergency Services,
Mahadevapura Fire Station
Garudachara Palya, Bengaluru-560 048.**



C.No.89/DFO/MFS/RFSCR/2025

Dated: 29-07-2025.

ANNEXURE – 2

Group - B Educational Building

To,

The Authorised Signatory,
M/s. East Bangalore School
Sri Nelasiri Educational Trust
No:76/2, Gundur Village, Bidarahalli Hobli,
Virgonagar Post, Bangalore East,
Bangalore-560067.

Sir,

Sub : Issue of “Renewal of “Fire Safety Compliance Report” with respect to fire prevention, fire fighting and evacuation measures maintained at “M/s. East Bangalore School, Sri Nelasiri Educational Trust, No:76/2, Gundur Village, Bidarahalli Hobli, Virgonagar Post, Bangalore East, Bangalore”- reg.

- Ref :**
- 1) FSR No.01/RFO/BLR-East/FSR/2022, Dt: 29-01-2022.
 - 2) FSCR No.01/RFO/BLR-East/FSR/2022, Dt:31-01-2022.
 - 3) RFSCR No.18/DFO/MFS/FSCR/2023, Date: 03-03-2023.
 - 4) RFSCR No.74/RCC/DFO/MFS/2024, Date:19-07-2024.
 - 5) Your request letter dated: 18-07-2024.

<<<>>>

With reference to the above cited subject, as per ref(1), a Conditional Fire Safety recommendation was issued to the premises of at “M/s.East Bangalore School, Sri Nelasiri Educational Trust, No:76/2, Gundur Village, Bidarahalli Hobli, Virgonagar Post, Bangalore East, Bangalore-560067.” with a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, “Fire Safety Compliance Report” and as per reference (3)&(4) “Renewal Fire safety Compliance Report” was issued for the above building. Now the management of “M/s. East Bangalore School” had requested for the Renewal of fire safety compliance Report from our department. In this regard the above addressed educational building was inspected by me on 21-07-2025 for Renewing the fire safety compliance report.



Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the **“Renewal Fire Safety Compliance Report”** to **“M/s. East Bangalore School, Sri Nelasiri Educational Trust No:76/2, Gundur Village Bidarahalli Hobli, Virgonagar Post, Bangalore East, Bangalore”** subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report.

This fire Safety Compliance Report is issued from the Fire Prevention and Fire Fighting Point of view Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.

in case the fire prevention and firefighting measures installed in the building as per the recommendation of the department are not maintained in good working condition, if the evacuation measures are not properly followed and if any additional construction work is taken up in the Building/premises, this fire safety Compliance Report deemed to be cancelled and necessary legal action will be initiated against the developer/management/tenant and also separate NOC has to be obtained from the department for the storage of Chemicals, Solvents, Petroleum products (Diesel, Petrol), LPG etc in the premises/ building.

“This Fire safety compliance Report is valid for Only Two Year’s from the date of issue and it is renewable without fail”.

Yours faithfully


District Fire Officer
Karnataka Fire & Emergency Services
Mahadevapura Fire Station,
Bengaluru - 560048
29/02/25